



**DESIGN DATA & GENERAL NOTES**

- 1) CONCRETE: 4,000 PSI @ 28 DAYS.
- 2) CEMENT: TYPE III PER ASTM C150-81.
- 3) REINFORCEMENT: GRADE 60 REBAR.
- 4) OPENINGS SIZED FOR 2" & 4" CONDUITS.
- 5) MEETS ALL CENTRAL MAINE POWER SPECIFICATIONS.
- 6) SUITABLE FOR SECONDARY CABLE INSTALLATIONS.
- 7) IF INSTALLED IN A PAVED AREA, ORDER PRECAST SLAB FOR USE UNDER HANDHOLE FOR ADDITIONAL LOAD BEARING OF TRAFFIC.
- 8) ORDER 32" DIAMETER "CMP CO." & "TELEPHONE" OR FRAME & COVER MIN. ONE COURSE OF BRICK TO GRADE.

4' X 4' UTILITY VAULT

[www.georgerobertsco.com](http://www.georgerobertsco.com)

**George R. Roberts Co.**  
Precast Concrete Products

192 Biddeford Road Phone 207-324-6571  
Alfred, Maine 04002 Fax 207-324-8533